



Rachel Morris
Senior Licensing Assistant
licensing@bridgend.gov.uk

Our Ref: SJT/01E-15055 LA02
Your Ref:

Date: 31 December 2014

Contact: Station Manager St.John Towell
Tel: 07900227722
E-mail: firesafety@southwales-fire.gov.uk

Dear Madam

**LICENSING ACT 2003
APPLICATION FOR: GRANT OF PREMISES LICENCE.
AT: 33 MARKET STREET, BRIDGEND, CF31 1LJ**

REPRESENTATIONS AGAINST THE APPLICATION

On behalf of the Fire and Rescue Authority, notice is hereby given of representations against the present application in respect of the above. The grounds for the representations are detailed in the enclosed report.

This authority cannot enforce these matters directly under current fire safety regulations until such times as persons are employed on the premises.

Please quote our reference in all future correspondence.

Yours faithfully

Signed  Print Name ST.JOHN TOWELL
for Assistant Chief Fire Officer

Cc saimarasul@yahoo.co.uk

SOUTH WALES FIRE AUTHORITY

LICENSING ACT 2003

NOTICE OF REPRESENTATIONS

NAME AND ADDRESS OF PREMISES: 33 Market Street, Bridgend, CF31 1LJ

APPLICANT: Zahid Rasul

APPLICATION FOR: Grant of a Premises Licence

REASON FOR REPRESENTATIONS: This authority is of the opinion that the application, as submitted, does not appear to adequately promote the PUBLIC SAFETY licensing objective.

DATE OF INSPECTION: 30 December 2014

FIRE SAFETY OFFICER: SM St.John Towell

The Fire Authority makes representations against this application on the following grounds: -

An assessment of the plans provided has been carried out and the proposed means of escape is inadequate for the available floor space and potential occupancy figure. Our calculations identify sufficient exit capacities to be approximately 280 with available floor space close to 700 people. The proposed situation is unacceptable to this authority and the applicant is advised to contact the above Officer to discuss the matter.